



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					04.02.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPPC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	264	238	416	4	44	1.3
		outlet	7.5	46	28	112	3	42	0.8
	45 MGD	Inlet	7.4	314	240	448	4	43	1.4
		outlet	7.6	31	19	72	Nil	41	1
	37 MGD	Inlet	7.4	314	240	448	4	43	1.4
		outlet	7.6	46	26	104	2	40	1.2
	16 MGD	Inlet	7.4	314	240	448	4	43	1.4
		outlet	7.5	50	29	120	3	42	1
	New 30 MGD	Inlet	7.3	426	255	480	-	44	1.8
		Outlet	7.6	9	7	32	-	2	0.4
Kondli	25 MGD Phase-II	Inlet	7.2	362	200	321	-	38	6.9
		outlet	7.5	30	19	62	-	32	3.2
	45 MGD Phase-IV	Inlet	7.2	362	200	321	-	38	6.9
		outlet	7.6	21	13	58	-	31	2.5
Chilla	9 MGD	Inlet	7.2	200	95	-	-	40	6.8
		outlet	7.6	9	4	-	-	0.32	4.3
CWG Village	1 MGD	Inlet	7.2	496	360	-	-	24	4.5
		outlet	7.7	1	0.73	-	-	0.18	1.8
Yamuna Vihar	10 MGD Phase-I	Inlet	6.9	256	189	569	78.8	55	7.5
		outlet	7.5	48	27	-	20	25	4
	25 MGD Phase-III	Inlet	7.1	268	178	592	84.4	40	8.5
		outlet	7.6	27	15	-	25.6	20	4.5
Rithala	40 MGD	Inlet	7	280	157	340	-	29	0.9
		outlet	7.8	27	18	70	-	16	0.5
	40 MGD	Inlet	7	280	157	340	-	29	0.9
		Outlet	7.6	16	12	50	-	12	0.4
Keshopur	12 MGD	Inlet	7.2	376	252	720	12	31	3.4
		outlet	7.5	11	5	32	Nil	5	2
	40 MGD	Inlet	7.3	520	255	-	14.6	32	3.6
		outlet	7.5	68	38	-	2.2	31	3
	20 MGD	Inlet	7.3	520	255	-	14.6	32	3.6
		outlet	7.4	146	139	-	5.4	29	3.2
Nazafgarh	5 MGD	Inlet	7.3	203	112	-	-	22	3
		outlet	7.6	36	22	-	-	18	2.2
PappanKalan	20 MGD Phase-I	Inlet	7.3	469	191	520	-	24	3.2
		outlet	7.5	48	22	-	-	20	1.6
	20 MGD Phase-II	Inlet	7.3	469	191	520	-	24	3.2
		outlet	7.5	7	7	20	-	14	2.4
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	280	220	394	-	31	2
		outlet	7.5	86	46	146	-	26	1.6
	10 MGD Phase-III	Inlet	7.1	310	295	348	-	46	2.8
		outlet	7.4	45	27	98	-	26	1.4

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	04.02.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	46	28	112
	45 MGD	31	19	72
	37 MGD	46	26	104
	16 MGD	50	29	120
	New 30 MGD	9	7	32
Kondli	25 MGD Pahse-II	30	19	62
	45 MGD Phase-IV	21	13	58
Chilla	9 MGD	9	4	-
CWG Village	1 MGD	1	0.73	-
Yamuna Vihar	10 MGD Phase-I	48	27	-
	25 MGD Phase-III	27	15	-
Rithala	40 MGD Phase-I	27	18	70
	40 MGD Phase-II	16	12	50
Keshopur	12 MGD	11	5	32
	40 MGD	68	38	-
	20 MGD	146	139	-
Nazafgarh	5 MGD	36	22	-
PappanKalan	20 MGD Phase-I	48	22	-
	20 MGD Phase-II	7	7	20
Corronation pillar	20 MGD Pahse-I & II	86	46	146
	10 MGD Pahse-III	45	27	98



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					05.02.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	192	181	432	4	42	1.5
		outlet	7.6	43	25	96	2	40	0.5
	45 MGD	Inlet	7.4	218	197	472	4	44	1.5
		outlet	7.7	34	21	80	Nil	38	0.8
	37 MGD	Inlet	7.4	218	197	472	4	44	1.5
		outlet	7.7	37	24	88	2	40	1
	16 MGD	Inlet	7.4	218	197	472	4	44	1.5
		outlet	7.6	49	27	112	4	44	0.8
Kondli	25 MGD Phase-II	Inlet	7.3	324	202	302	18	34	7.2
		outlet	7.6	16	11	48	3	28	3.7
	45 MGD Phase-IV	Inlet	7.3	324	202	302	18	34	7.2
		outlet	7.5	44	24	74	4.5	30	3
Chilla	9 MGD	Inlet	7.1	264	140	152	16	39	6.7
		outlet	7.6	8	4	16	2.8	0.24	4.3
CWG Village	1 MGD	Inlet	7.2	644	357	385	28	23	4.8
		outlet	7.7	1	0.55	Bdl	Bdl	0.12	1.7
Delhi Gate Nallah	2.2 MGD	Inlet	7.3	256	225	-	-	42	1.5
		outlet	7.6	5	6	-	-	8	0.4
	15 MGD	Inlet	7.4	124	142	-	-	40	1.6
		outlet	7.5	5	7	-	-	7	0.5
Sen Nursing Home	2.2 MGD	Inlet	7.4	224	210	-	-	42	1.8
		outlet	7.6	7	8	-	-	10	0.5
Yamuna Vihar	10 MGD Phase-I	Inlet	7	272	203	589	-	55	6.5
		outlet	7.5	43	24	-	-	20	4
	25 MGD Phase-III	Inlet	7.2	336	231	642	-	60	7.5
		outlet	7.6	29	19	-	-	30	4.5
Rithala	40 MGD	Inlet	7.1	264	163	360	-	35	1.4
		outlet	7.6	29	20	80	-	20	0.7
	40 MGD	Inlet	7.1	264	163	360	-	35	1.4
		Outlet	7.7	17	11	60	-	14	0.5
Keshopur	12 MGD	Inlet	7.2	352	210	613	-	36	3.5
		outlet	7.4	10	6	30	-	3	1.9
	40 MGD	Inlet	7.3	304	229	587	-	32	3.4
		outlet	7.5	74	48	148	-	32	2.9
	20 MGD	Inlet	7.3	304	229	587	-	32	3.4
		outlet	7.3	152	141	422	-	34	3.3
Nazafgarh	5 MGD	Inlet	7.3	171	-	210	-	22	-
		outlet	7.6	23	-	50	-	14	-
PappanKalan	20 MGD Phase-I	Inlet	7.3	195	-	-	-	28	-
		outlet	7.5	58	-	-	-	20	-
	20 MGD Phase-II	Inlet	7.3	195	-	0	-	28	-
		outlet	7.5	6	-	-	-	1.8	-
	20 MGD	Inlet	7	248	205	288	-	34	2.5

Corronation pillar	Phase-I &II	outlet	7.5	58	34	98	-	24	1.4
	10 MGD	Inlet	7.2	288	275	274	-	41	2.5
	Phase-III	outlet	7.5	32	23	62	-	27	1.2

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	05.02.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	43	25	96
	45 MGD	34	21	80
	37 MGD	37	24	88
	16 MGD	49	27	112
Kondli	25 MGD Pahse-II	16	11	48
	45 MGD Phase-IV	44	24	74
Chilla	9 MGD	8	4	16
CWG Village	1 MGD	1	0.55	Bdl
Delhi Gate Nallah	2.2 MGD Pahse-I	5	6	-
	15 MGD Pahse-II	5	7	-
Sen Nursing Home	2.2 MGD	7	8	-
Yamuna Vihar	10 MGD Phase-I	43	24	-
	25 MGD Phase-III	29	19	-
Rithala	40 MGD Phase-I	29	20	80
	40 MGD Phase-II	17	11	60
Keshopur	12 MGD	10	6	30
	40 MGD	74	48	148
	20 MGD	152	141	422
Nazafgarh	5 MGD	23	-	50
PappanKalan	20 MGD Phase-I	58	-	-
	20 MGD Phase-II	6	-	-
Corronation pillar	20 MGD Pahse-I & II	58	34	98
	10 MGD Pahse-III	32	23	62



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					06.02.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	296	270	400	3	38	1.5
		outlet	7.7	46	27	112	2	30	0.8
	45 MGD	Inlet	7.4	274	280	416	3	40	1.8
		outlet	7.7	21	17	64	Nil	36	0.8
	37 MGD	Inlet	7.4	274	280	416	3	40	1.8
		outlet	7.7	21	14	56	Nil	37	1
	16 MGD	Inlet	7.4	274	280	416	3	40	1.8
		outlet	7.6	49	28	112	3	42	0.5
Kondli	25 MGD Phase-II	Inlet	7.3	356	177	242	19	38	7.1
		outlet	7.6	17	10	36	2.8	27	3.9
	45 MGD Phase-IV	Inlet	7.4	410	221	360	21	38	6.8
		outlet	7.5	24	16	50	4.2	32	3.4
Chilla	9 MGD	Inlet	7.1	172	102	140	14.8	42	6.5
		outlet	7.6	7	2.9	16	2.5	0.23	4.5
CWG Village	1 MGD	Inlet	7.1	1468	411	780	32	22	5.9
		outlet	7.6	6	1.2	1.8	Bdl	0.19	1.4
Yamuna Vihar	10 MGD Phase-I	Inlet	7	244	178	552	-	55	6.5
		outlet	7.4	49	28	102	-	35	4.5
	25 MGD Phase-III	Inlet	7.2	332	225	630	-	50	7.5
		outlet	7.6	30	17	79	-	40	3.5
Rithala	40 MGD	Inlet	6.9	272	149	320	-	32	1.9
		outlet	7.6	28	17	70	-	18	0.8
	40 MGD	Inlet	6.9	272	149	320	-	32	1.9
		Outlet	7.5	16	11	60	-	15	0.6
Keshopur	12 MGD	Inlet	7.3	464	250	-	13.8	34	3.2
		outlet	7.5	12	5	-	Nil	4	2.1
	40 MGD	Inlet	7.2	508	233	-	13	32	3.4
		outlet	7.5	62	40	-	2	30	2.8
	20 MGD	Inlet	7.2	508	233	-	13	32	3.4
		outlet	7.4	216	158	-	5.9	33	2.9
Nazafgarh	5 MGD	Inlet	7.3	134	129	-	-	28	3
		outlet	7.6	26	23	-	-	14	2
PappanKalan	20 MGD Phase-I	Inlet	7.3	271	246	-	-	28	3.2
		outlet	7.5	79	37	-	-	20	1.6
	20 MGD Phase-II	Inlet	7.3	271	246	-	-	28	3.2
		outlet	7.5	5	2	-	-	1.4	2
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	262	210	340	7	37	2.4
		outlet	7.5	56	32	84	3.1	26	2.2
	10 MGD Phase-III	Inlet	7.1	310	290	304	8.1	42	2
		outlet	7.4	42	25	88	3	25	1

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	06.02.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	46	27	112
	45 MGD	21	17	64
	37 MGD	21	14	56
	16 MGD	49	28	112
Kondli	25 MGD Pahse-II	17	10	36
	45 MGD Phase-IV	24	16	50
Chilla	9 MGD	7	2.9	16
CWG Village	1 MGD	6	1.2	1.8
Yamuna Vihar	10 MGD Phase-I	49	28	102
	25 MGD Phase-III	30	17	79
Rithala	40 MGD Phase-I	28	17	70
	40 MGD Phase-II	16	11	60
Keshopur	12 MGD	12	5	-
	40 MGD	62	40	-
	20 MGD	216	158	-
Nazafgarh	5 MGD	26	23	-
PappanKalan	20 MGD Phase-I	79	37	-
	20 MGD Phase-II	5	2	-
Corronation pillar	20 MGD Pahse-I & II	56	32	84
	10 MGD Pahse-III	42	25	88



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					07.02.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPPC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.4	288	178	464	5	38	1.8
		outlet	7.6	40	27	104	3	42	1.5
	45 MGD	Inlet	7.4	232	173	440	5	42	2
		outlet	7.5	45	28	104	3	40	0.5
	37 MGD	Inlet	7.4	232	173	440	5	42	2
		outlet	7.7	35	24	96	2	40	0.8
	16 MGD	Inlet	7.4	232	173	440	5	42	2
		outlet	7.6	40	26	104	2	42	1
	New 30 MGD	Inlet	7.3	338	210	496	-	45	2.5
		Outlet	7	5	6	24	-	8	1.8
Kondli	25 MGD Phase-II	Inlet	7.4	382	174	314	19.5	37	6.5
		outlet	7.8	15	9	34	2.5	22	3.7
	45 MGD Phase-IV	Inlet	7.3	418	195	374	22	40	6.8
		outlet	7.6	26	17	56	3.8	34	3
Chilla	9 MGD	Inlet	7.1	272	160	224	15.5	39	6.9
		outlet	7.6	7	3.4	18	2.2	0.2	4.5
CWG Village	1 MGD	Inlet	7.2	1136	420	528	30	22	4.7
		outlet	7.7	Bdl	0.25	Bdl	Bdl	0.08	1.8
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	240	181	538	-	50	8
		outlet	7.4	46	26	97	-	20	5
	25 MGD Phase-III	Inlet	7.2	312	201	609	-	55	7
		outlet	7.5	28	16	59	-	30	4.5
Rithala	40 MGD	Inlet	7	260	158	-	27	34	1.8
		outlet	7.6	28	19	-	7	20	0.7
	40 MGD	Inlet	7	260	158	-	27	34	0.5
		Outlet	7.8	18	12	-	5	15	
Keshopur	12 MGD	Inlet	7.3	412	178	-	-	31	3.4
		outlet	7.5	11	6	-	-	4	2.2
	40 MGD	Inlet	7.3	390	172	-	-	30	3.3
		outlet	7.5	76	41	-	-	31	2.9
	20 MGD	Inlet	7.3	390	172	-	-	30	3.3
		outlet	7.4	188	147	-	-	28	3
Nazafgarh	5 MGD	Inlet	7.3	247	215	-	-	22	3
		outlet	7.6	31	15	-	-	14	2
PappanKalan	20 MGD Phase-I	Inlet	7.3	171	165	-	-	26	3.2
		outlet	7.5	29	18	-	-	18	1.6
	20 MGD Phase-II	Inlet	7.3	171	165	-	-	26	3.2
		outlet	7.5	9	3	-	-	1.4	2
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	368	230	410	-	35	2.6
		outlet	7.4	64	34	102	-	26	1.7
	10 MGD Phase-III	Inlet	7.2	324	295	436	-	40	2.3
		outlet	7.5	40	24	90	-	32	1.2

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	07.02.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	40	27	104
	45 MGD	45	28	104
	37 MGD	35	24	96
	16 MGD	40	26	104
	New 30 MGD	5	6	24
Kondli	25 MGD Pahse-II	15	9	34
	45 MGD Phase-IV	26	17	56
Chilla	9 MGD	7	3.4	18
CWG Village	1 MGD	Bdl	0.25	Bdl
Yamuna Vihar	10 MGD Phase-I	46	26	97
	25 MGD Phase-III	28	16	59
Rithala	40 MGD Phase-I	28	19	-
	40 MGD Phase-II	18	12	-
Keshopur	12 MGD	11	6	-
	40 MGD	76	41	-
	20 MGD	188	147	-
Nazafgarh	5 MGD	31	15	-
PappanKalan	20 MGD Phase-I	29	18	-
	20 MGD Phase-II	9	3	-
Corronation pillar	20 MGD Pahse-I & II	64	34	102
	10 MGD Pahse-III	40	24	90



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					08.02.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	208	228	416	4	40	1
		outlet	7.6	40	21	80	2	40	1.5
	45 MGD	Inlet	7.3	394	320	504	4	42	1.2
		outlet	7.7	30	17	64	2	36	1.5
	37 MGD	Inlet	7.3	394	320	504	4	42	1.2
		outlet	7.7	28	16	56	1	38	0.8
	16 MGD	Inlet	7.3	394	320	504	4	42	1.2
		outlet	7.6	40	22	88	3	45	Nil
Kondli	25 MGD Phase-II	Inlet	7.3	494	224	438	14	37	6.8
		outlet	7.6	22	13	46	3	30	3.2
	45 MGD Phase-IV	Inlet	7.4	446	224	418	21	40	7
		outlet	7.5	28	16	58	4	32	2.9
Chilla	9 MGD	Inlet	7.1	320	180	294	18	40	6.4
		outlet	7.6	9	4	22	3	0.28	4.7
CWG Village	1 MGD	Inlet	7.1	1290	548	669	28	23	4.5
		outlet	7.7	1	0.75	0.8	Bdl	0.12	1.8
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	204	149	518	-	45	6
		outlet	7.5	44	25	91	-	20	3.5
	25 MGD Phase-III	Inlet	7.2	304	191	572	-	50	7
		outlet	7.6	26	17	63	-	30	3
Rithala	40 MGD	Inlet	7	232	150	260	-	28	0.8
		outlet	7.6	27	17	60	-	14	0.4
	40 MGD	Inlet	7	232	150	260	-	28	0.8
		Outlet	7.5	16	12	40	-	12	0.3
Keshopur	12 MGD	Inlet	7.2	430	229	667	21	28	3.2
		outlet	7.5	12	7	32	Nil	3	1.9
	40 MGD	Inlet	7.2	412	224	720	17.4	32	3.1
		outlet	7.5	86	53	180	1.6	30	2.6
	20 MGD	Inlet	7.2	412	224	720	17.4	32	3.1
		outlet	7.4	224	157	480	6.8	24	2.8
PappanKalan	20 MGD Phase-I	Inlet	7.5	146	90	-	5	18	2.2
		outlet	7.2	25	12	-	Nil	14	1.2
	20 MGD Phase-II	Inlet	7.5	146	90	-	5	18	2.2
		outlet	7.4	3	2	-	Nil	1.4	1.8
Corronation pillar	20 MGD Phase-I & II	Inlet	7.2	280	258	349	5.8	36	2.4
		outlet	7.5	49	29	98	2.6	24	1.3
	10 MGD Phase-III	Inlet	7.2	368	230	416	6.8	43	2.4
		outlet	7.6	33	22	72	2.6	28	1.1

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	08.02.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	40	21	80
	45 MGD	30	17	64
	37 MGD	28	16	56
	16 MGD	40	22	88
Kondli	25 MGD Pahse-II	22	13	46
	45 MGD Phase-IV	28	16	58
Chilla	9 MGD	9	4	22
CWG Village	1 MGD	1	0.75	0.8
Yamuna Vihar	10 MGD Phase-I	44	25	91
	25 MGD Phase-III	26	17	63
Rithala	40 MGD Phase-I	27	17	60
	40 MGD Phase-II	16	12	40
Keshopur	12 MGD	12	7	32
	40 MGD	86	53	180
	20 MGD	224	157	480
Pappankalan	20 MGD Phase-I	25	12	-
	20 MGD Phase-II	3	2	-
Corronation pillar	20 MGD Pahse-I & II	49	29	98
	10 MGD Pahse-III	33	22	72



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



		Parameters of STPs of Delhi as on					09.02.2019		
Name of the Plant	Capacity (in MGD)	Parameter							
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	O&G	NH4-H	PO4
		DPCC limits	5.5-9.0	50	30	250	10	50	5
Okhla	12 MGD	Inlet	7.3	208	235	424	5	40	1.8
		outlet	7.6	39	21	80	2	43	2.8
	45 MGD	Inlet	7.4	250	220	416	5	42	2.5
		outlet	7.7	30	19	72	Nil	40	1.2
	37 MGD	Inlet	7.4	250	220	416	5	42	2.5
		outlet	7.7	40	21	80	2	43	1.2
	16 MGD	Inlet	7.4	250	220	416	5	42	2.5
		outlet	7.7	34	20	72	3	42	1
Kondli	25 MGD Phase-II	Inlet	7.2	272	184	338	20.8	39	7.1
		outlet	7.6	21	11	42	2.9	29	3.7
	45 MGD Phase-IV	Inlet	7.2	316	212	408	28.4	36	6.8
		outlet	7.5	27	17	54	3.6	31	3.3
Yamuna Vihar	10 MGD Phase-I	Inlet	7.1	212	144	529	62.4	55	6.5
		outlet	7.5	41	22	83	21.6	25	2.5
	25 MGD Phase-III	Inlet	7.2	312	195	629	72.8	50	5.5
		outlet	7.6	24	15	71	27.6	20	3
Rithala	40 MGD	Inlet	7.1	252	154	370	-	30	1.2
		outlet	7.7	29	19	80	-	15	0.4
	40 MGD	Inlet	7.1	252	154	370	-	30	1.2
		Outlet	7.6	16	12	60	-	12	0.3
Keshopur	12 MGD	Inlet	7.2	416	249	746	16	29	3.1
		outlet	7.5	18	7	34	0.4	3	1.9
	40 MGD	Inlet	7.2	400	262	780	13.6	30	3.4
		outlet	7.5	63	37	142	1.6	29	2.8
	20 MGD	Inlet	7.2	400	262	780	13.6	30	3.4
		outlet	7.4	186	163	486	5.4	26	2.9
PappanKalan	20 MGD Phase-I	Inlet	7.3	177	150	-	-	18	2.2
		outlet	7.5	49	26	-	-	14	1.2
	20 MGD Phase-II	Inlet	7.3	177	150	-	-	18	2.2
		outlet	7.5	3	3	-	-	1.4	1.8
Corronation pillar	20 MGD Phase-I & II	Inlet	7.1	275	235	338	-	39	2.1
		outlet	7.5	46	27	95	-	25	1.1
	10 MGD Phase-III	Inlet	7.2	330	285	408	-	40	2.3
		outlet	7.5	32	24	68	-	27	1.2

Dir.(T&QC)



OFFICE OF THE DIRECTOR (T&QC)
DELHI JAL BOARD: GOVT. OF NCT OF DELHI
WATER WORKS WAZIRABAD:DELHI-110054



Name of the Plant	Capacity (in MGD)	09.02.2019		
		TSS (mg/l)	BOD (mg/l)	COD (mg/l)
		50	30	250
Okhla	12 MGD	39	21	80
	45 MGD	30	19	72
	37 MGD	40	21	80
	16 MGD	34	20	72
Kondli	25 MGD Pahse-II	21	11	42
	45 MGD Phase-IV	27	17	54
Yamuna Vihar	10 MGD Phase-I	41	22	83
	25 MGD Phase-III	24	15	71
Rithala	40 MGD Phase-I	29	19	80
	40 MGD Phase-II	16	12	60
Keshopur	12 MGD	18	7	34
	40 MGD	63	37	142
	20 MGD	186	163	486
PappanKalan	20 MGD Phase-I	49	26	-
	20 MGD Phase-II	3	3	-
Corronation pillar	20 MGD Pahse-I & II	46	27	95
	10 MGD Pahse-III	32	24	68